

Hydrant Certificate



Development: _____ Date: _____

Address: _____ Time: _____

Hydrant No. or Identifier: _____

Hydrant Location: _____

Hydrant Make: _____

Pumper Port: _____

Hydrant Model: _____

T.P.I.-LG-SM: _____

No. of Ports: _____

Nut Syle: _____

Isolation Valve Location: _____

Static Pressure: _____ PSI

Flow Pressure: _____ PSI GPM (US): _____ L/S: _____

Residual Pressure: _____ PSI

Is hydrant painted red with white trim? Yes No

Is hydrant cap painted according to flow rate? Yes No

Flow Rate	Required Color
>99l/s	Light Blue
66l/s to 99l/s	Green
33l/s to 65l/s	Orange
<33l/s	Red

Comments: _____

Inspected By: _____

Signature: _____